

Product Name :
Generator HMI Control Unit

Product Code :
NEC-18-06-18-0092



Description :

Generator HMI Control Unit

Technical Specification :

Minimum Technical Specification Required :

- Three-phase measurement of current and voltage 3x400V/5A
- Measurement of phase voltages, line-to-line voltages and currents
- Determination of the apparent, active and reactive power
- Determination of active, reactive and apparent work
- Determination of the frequency and distortion factors for current and voltage
- Detection of mains harmonic oscillations and neutral conductor current

- Pulse measurement
- Peak and mean value detection
- Event logging and Realtime clock
- Ethernet interface

Electrical and Electronics

Website: www.electricelectronicsindia.com, **Email:** export@electricelectronicsindia.com

Address: 6148/6, Guru Nanak Marg, Ambala Cantt, Haryana, India, **Phone:** +91-0171-2643080, 2601773